

NON-RETURN VALVES: To Section SP25 and the following:

INFORMATION TO BE SUPPLIED (See DR 99004 CP [or AS/NZS 4592])	PROJECT REQUIREMENTS (* See Practices Table of Sections SP25 & SP30)
Valve size(s), class(es) and flange class(es)	
Materials: - Body - Disc - Body seat ring - Disc facing rings - Hinge - Bolting - Plug	- - - - - - -
Counter weight(s) and lever(s)	
Flanged joint bolting selection (fasteners)	
Coatings	*
Additional testing	
Acceptable Product Verification Report	Manufacturers without Product Cert. to supply
Flange gaskets, O-rings and lubricants	
Bactericidal lubricant	
Type Test Results	If no Aust. Std., manufacturer to supply
Certificate of Compliance, Section SP25	Manufacturer to supply
Test Certificate of Results, obtained to establish compliance to Section SP25	If no Aust. Std., manufacturer to supply